

BRYLAND

Fire Protection

Pear Tree Lane,
Dudley, West Midlands
DY2 0QY
tel 01384 573350
www.brylandfire.com

BRITISH APPROVALS FOR FIRE EQUIPMENT SCHEME: SP101/ST104 CONTRACT MAINTENANCE OF PORTABLE FIRE EXTINGUISHERS

This is to certify that

BRYLAND

Fire Protection

Have inspected the portable fire extinguishers at your premises and have carried out a service in accordance with British Standard 5306 Part 3:2009 and to the requirements of BAFE SP101/ST104.


Engineer..... *SIMON EVANS* Location..... *QUINTON MOTOR CLUB*

Engineer Signature..... *[Signature]* Maintenance Technician..... *JP EVANS*

Date of Service..... *DECEMBER 2022* Next Service Due..... *DECEMBER 2023*

Recommendations to user

Monthly inspection should be made by the user or the user's representative, to make sure that appliances are correctly positioned and have not been tampered with in any way. Checks should also be made to ensure that the appliances have not been discharged or, where indicated by the gauge, lost pressure. In this event, it is advised that you contact Bryland Fire Protection Limited as soon as possible to bring your appliances to a satisfactory standard and maintain the coverage of your fire certificate.



Bryland Fire Protection Limited are Registered to BS EN ISO9001:2008 FS593152

certificate of Inspection NO: 161248

BRYLAND Fire

Date... 21ST DECEMBER 2022

PROTECTION LIMITED

Unit 3, Pear Tree Lane, Dudley,
West Midlands DY2 0QY
Tel: 01384 573350/573301
Sales Fax: 01384 480944
Email: sales@brylandfire.co.uk
www.brylandfire.co.uk
VAT. Reg No. 281 2496 51

| | | | |
|---|----------|---|--|
| INVOICE ADDRESS <u>QUINTON MOTOR CLUB, c/o NEIL CROSS 14 DAMSON PARK, PATTINGHAM, SOUTH STAFFS, WV6 7AY.</u> | | SITE ADDRESS <u>QUINTON MOTOR CLUB, c/o NEIL CROSS 6 WOWERHAMPTON ROAD, PATTINGHAM, SOUTH STAFFS</u> | |
| CONTACT <u>NEIL CROSS</u> | ORDER NO | TELEPHONE NO. <u>07767 773862</u> | |

TECHNICIAN

APART FROM THE NON-CONFORMING EXTINGUISHERS AS RECORDED, ALL PORTABLE FIRE EXTINGUISHERS HAVE BEEN INSPECTED AND SERVICED IN ACCORDANCE WITH BRITISH STANDARD BS 5306-3.

SERVICE/
CALL OUT

| TYPE & SIZE | TOTAL INSPECTED | CONDEMNED | MISSING | SUPPLIED NEW | TRAINING | EXTENDED SERVICE | REFILLED | RENOVATED & REFILLED |
|----------------------|-----------------|-----------|---------|--------------|----------|------------------|----------|----------------------|
| WATER | 9L | | | | | | | |
| AFFF FOAM | 1L | | | | | | | |
| | 2L | | | | | | | |
| | 6L | 9 | | | | | | |
| | 9L | 3 | | | | 1 | 1 | |
| WATER ADDITIVE EXT'S | 6L | | | | | | | |
| WET CHEMICAL CLASS F | 3L | | | | | | | |
| | 6LT | | | | | | | |
| POWDER | 1KG | | | | | | | |
| | 2KG | | | | | | | |
| | 4KG | | | | | | | |
| | 6KG | 11 | | | | 2 | 3 | |
| | 9KG | 1 | | | | 1 | 1 | |
| CARBON DIOXIDE | 2KG | | | | | | | |
| | 5KG | | | | | | | |
| HOSE REEL | | | | | | | | |
| FIRE BLANKET | | | | | | | | |

| PARTS | QTY |
|-------------------------|-----|
| ANTI-TAMPER SEAL | 24 |
| SAFETY PIN | |
| SAFETY CLIP/OK IND. | |
| SWIVEL HORN | |
| HOSE & HORN | |
| J-BRACKET | |
| CO ² BRACKET | |
| WALL FIXING | |
| CO ² VALVE | |
| HOSE REEL NOZZLE | |
| 19mm HOSE | |
| ENVIRONMENTAL DISPOSAL | 4 |
| O'RINGS | 24 |
| SIGNS: | |
| GAUGE DOGS | 24 |

TOTAL EQUIPMENT ON SITE FOLLOWING FULL SERVICE

| | |
|---------------------|--------------|
| EXTINGUISHERS 24 | BLANKETS |
| HOSE REELS | TROLLEY UNIT |

| |
|----------|
| TIME IN |
| TIME OUT |
| MILEAGE |

GUIDANCE TO CLIENTS:
REF. BS5306-3 PARA 5:
MONTHLY INSPECTIONS.

AT LEAST MONTHLY (SEE OVER - PARA 5). THESE INSPECTIONS MUST BE RECORDED AND THE RESPONSIBLE PERSON SHOULD ARRANGE FOR CORRECTIVE ACTION BY A COMPETENT PERSON WHERE NECESSARY.

COMMENTS FRA N/A FEB N

NEXT INSPECTION DUE: DECEMBER 2023

SERVICE-ENGINEER

SIGNATURE ON BEHALF OF CUSTOMER

SIGN [Signature]

SIGN [Signature]

PRINT NAME SPEVANS

PRINT NAME Neil Cross

DOC064(V1)

