

BRYLAND

Fire Protection

Pear Tree Lane,
Dudley, West Midlands
DY2 0QY
tel 01384 573350
www.brylandfire.com

BRITISH APPROVALS FOR FIRE EQUIPMENT SCHEME: SP101/ST104 CONTRACT MAINTENANCE OF PORTABLE FIRE EXTINGUISHERS

This is to certify that

Bryland Fire Protection

Have inspected the portable fire extinguishers at your premises and have carried out a service in accordance with British Standard 5306 Part 3:2017 and to the requirements of BAFE SP101/ST104

Location *Quinton Motor Club*

Engineer Name *Andy Martin*


Engineer Signature *[Signature]*

Date of Service *Dec 2024*

Next Service Due *Dec 2025*

Recommendations to user

Monthly inspection should be made by the user or the user's representative, to make sure that appliances are correctly positioned and have not been tampered with in any way. Checks should also be made to ensure that the appliances have not been discharged or, where indicated by the gauge, lost pressure. In this event, it is advised that you contact Bryland Fire Protection Limited as soon as possible to bring your appliances to a satisfactory standard and maintain the coverage of your fire Risk Assessment.
(If you should require a Fire Risk Assessment please call us on 01384 - 573350)



Bryland Fire Protection Limited are Registered to BS EN ISO9001:2015